

State of California
Well Completion Report
 Form DWR 188 In Review 2/14/2025
 WCR2024-009701

Owner's Well Number 1 Date Work Began 09/16/2024 Date Work Ended 10/09/2024
 Local Permit Agency San Bernardino County DPH - Environmental Health Services Safe Drinking Water Permit Section
 Secondary Permit Agency _____ Permit Number 2024090564 Permit Date 09/11/2024

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name <u>GORDON, LE ETTA TRUST 4-25-14,</u>	Activity <u>New Well</u>
Mailing Address <u>P.O Box 104</u>	Planned Use <u>Water Supply Domestic</u>
City <u>Bayview</u> State <u>_____</u> ID <u>_____</u> Zip <u>83803</u>	

Well Location	
Address _____	APN <u>065625101</u>
City _____ Zip _____ County <u>San Bernardino</u>	Township <u>09 N</u>
Latitude <u>34</u> <u>49</u> <u>41.6639</u> N Longitude <u>-115</u> <u>3</u> <u>15.732</u> W	Range <u>18 E</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>36</u>
Dec. Lat. <u>34.82824</u> Dec. Long. <u>-115.05437</u>	Baseline Meridian <u>San Bernardino</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy <u>20 Ft</u> Location Determination Method <u>GPS</u>	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method <u>Direct Rotary</u> Drilling Fluid <u>Bentonite</u>	
Total Depth of Boring <u>640</u> Feet	
Total Depth of Completed Well <u>640</u> Feet	

Water Level and Yield of Completed Well	
Depth to first water _____ (Feet below surface)	
Depth to Static _____	
Water Level <u>96</u> (Feet) Date Measured <u>02/14/2025</u>	
Estimated Yield* <u>10</u> (GPM) Test Type <u>Air Lift</u>	
Test Length <u>28</u> (Hours) Total Drawdown _____ (feet)	
*May not be representative of a well's long term yield.	

Geologic Log - Free Form		
Depth from Surface	Feet to Feet	Description
0	5	Top soil
5	20	Fine gravel
20	80	Coarse Gravel
80	300	Decomposed Granite
300	320	Clay/Sand/Decomposed Granite
320	400	Decomposed Granite
400	640	Rock

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	80	Blank	PVC	OD: 6.900 in. SDR: 17 Thickness: 0.405 in.	0.405	6.9			
1	80	400	Screen	PVC	OD: 6.900 in. SDR: 17 Thickness: 0.405 in.	0.405	6.9	Milled Slots	0.063	
1	400	640	Screen	Low Carbon Steel	N/A	0.214	4.5	Milled Slots	0.02	steel

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	50	Cement	10.3 Sack Mix		
50	400	Filter Pack	Other Gravel Pack		
0	640	Filter Pack	Other Gravel Pack		

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	400	13
400	640	6

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	CHAMBERS CHOICE DRILLING		
	Person, Firm or Corporation		
6322 CAHUILLA AVENUE	TWENTYNINE	CA	92277
Address	City	State	Zip
Signed	<i>electronic signature received</i>	10/10/2024	924648
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

Attachments
1 40 Permit and map.pdf - Permit

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number
		N	W
Latitude Deg/Min/Sec		Longitude Deg/Min/Sec	
TRS:			
APN:			